



"ഭരണഭാഷ മാതൃഭാഷ"

ഫോൺ : 0483-2643070, (Off)9496793270  
 ഇ-മെയിൽ : [suptvpsvavch@gmail.com](mailto:suptvpsvavch@gmail.com)  
 Web: <http://www.kottakkalayurvedacollege.ac.in>

വൈദ്യരത്നം പി.എസ് വാര്യർ ആയുർവേദ കോളേജ് ആശുപത്രി,  
 കോട്ടക്കൽ, എടരിക്കോട്.പി.ഒ., മലപ്പുറം ജില്ല, പിൻ - 676 501.

കാട്ടേഷൻ നോട്ടീസ്

ഫയൽ നം എ 1/2146/2016/3

തീയതി - 14/01/2020

വൈദ്യരത്നം പി.എസ് വാരിയർ ആയുർവേദ കോളേജ് ആശുപത്രിയിൽ NABH Accreditation ലഭ്യമാക്കുന്നതിന്റെ ഭാഗമായി Fire Extinguishers, emergency & escape lighting system, Self Illuminated Exit signages എന്നിവ വിതരണം ചെയ്യുന്നതിനും സ്ഥാപിക്കുന്നതിനുമുള്ള മത്സര സ്വഭാവമുള്ള കാട്ടേഷൻ ക്ഷണിച്ചു കൊള്ളുന്നു

Sl no	Item	Specification	Quantity (Quote rate of single items with installation charge)
1	Fire Extinguisher ABC type 4Kg	Supply and fixing of 4KgABC/MAP Dry powder(Stored pressure) Type Fire Extinguisher. Pressurized with dry nitrogen gas at 15 bar. Design, construction and testing as per IS 15683 with fire rating 1A 8B, Body Hydrottested at 35 bar, Operating temperature -30°C to +55° C, external epoxy powder coating with PO red Shade No 538 of IS 5, Supplied with standard accessories. Make Ceasefire /Safex / Minimax/ Kanex / Equivalent	32
2	Fire Extinguisher ABC type 6Kg	Same as above	9
3	Gas cylinder CO2 2Kg	Supply and fixing of Carbon dioxide type fire extinguisher of 2.0 Kg CO2 Fire Extinguisher. Design, construction and testing as per IS 15683 with fire rating 21B. Operating temperature -30°C to +55° C, Supplied with body bearing IS 7285 mark and approved by CCoE tested at 250 Kg/cm2., fitted with ISI marked & CCoE	3

		approved valve as per IS 3224. CO2 Gas as per IS:15222. Externally painted with PO Red shade No 538 of IS 5, Supplied with standard accessories .Make Ceasefire /Safex / Minimax/ Kanex / Equivalent	
4	Emergency & escape lighting system	Emergency LED Exit Light with battery back up 4 Hrs minimum upto 8Hrs. Self contained rechargeable emergency light Conforms to IS: 9583 -1981	As per requirement
5	Self Illuminated Exit signages	Rigid sheet , size 12 X 4inch	As per requirement

**നിബന്ധനകൾ :**

1. ക്വട്ടേഷൻ സമർപ്പിക്കുന്നവർ ആശുപത്രി സന്ദർശിച്ച് ആശുപത്രി കെട്ടിടവും പരിസരവും കണ്ട ശേഷം മാത്രം ക്വട്ടേഷൻ സമർപ്പിക്കേണ്ടതാണ്.
2. മുദ്രവെച്ച ക്വട്ടേഷൻ 24.01.2020 നു ഉച്ചക്ക് 2.00 മണി വരെ സ്വീകരിക്കുന്നതാണ്
3. മുദ്ര വെച്ച ക്വട്ടേഷൻ അടങ്ങിയ കവറിനു പുറത്ത് "ആയുർവേദ കോളേജ് ആശുപത്രിയിലേക്ക് Fire Extinguishers വിതരണം ചെയ്യുന്നതും സ്ഥാപിക്കുന്നതും സംബന്ധിച്ച് " എന്ന് എഴുതിയിരിക്കണം.
4. ക്വട്ടേഷനുകൾ 24.01.2020 വൈകീട്ട് 3.00 മണിക്ക് ഹാജരുള്ള ക്വട്ടേഷൻ കാര്യമടയോ /അവർ അധികാരപ്പെടുത്തിയ പ്രതിനിധികളുടെയോ മുമ്പാകെ തുറക്കുന്നതാണ് .
5. ക്വട്ടേഷൻ സ്ഥിരപ്പെടുത്തി കിട്ടിയ ആൾ 15 ദിവസത്തിനുള്ളിൽ പ്രസ്തുത പ്രവൃത്തി ചെയ്യേണ്ടതാണ് .
6. കൂടുതൽ വിവരങ്ങൾക്ക് ഓഫീസുമായി ബന്ധപ്പെടേണ്ടതാണ്
7. ക്വട്ടേഷൻ സ്വീകരിക്കുന്നതിനും നിരസിക്കുന്നതിനുമുള്ള പരിപൂർണ്ണ അധികാരം ,സൂപ്രണ്ട്, ആയുർവേദ കോളേജ് ആശുപത്രി ,കോട്ടക്കൽ പക്കൽ നിക്ഷിപ്തമായിരിക്കും .

  
 സൂപ്രണ്ട്

To  
 നോട്ടീസ് ബോർഡ്  
 വില്ലേജ് ഓഫീസ്, കോട്ടക്കൽ /പഞ്ചായത്ത് ഓഫീസ്, എടരിക്കോട്  
 /മുൻസിപ്പൽ  
 ഓഫീസ്, കോട്ടക്കൽ  
 കെ എ എസ് ആർ എസ് /വിപിഎസ് വി ആയുർവേദ കോളേജ്/  
 വിപിഎസ് വി  
 ആയുർവേദ കോളേജ് ആശുപത്രി